

CHEMICAL LABORATORY (MALAYSIA) SDN BHD (27822-K)

81-85 (2nd & 3rd Floor), Jalan SS25/2, Taman Bukit Emas, 47301 Petaling Jaya, Selangor Darul Ehsan, Malaysia.

Tel: 03-7803 2229, 7803 9582, 7803 0386 Fax: 03-7803 2303

E-mail: clhq@chemlab.com.my Homepage: <http://www.chemlabgroup.com>

ASSAYERS, ANALYTICAL CHEMISTS, MICROBIOLOGISTS AND INDUSTRIAL CONSULTANTS

MS ISO/IEC 17025

TESTING
SAMM NO. 074

(GST : 001839865856)

Executive Chairman:

Dato' Dr. F.W. Kam

Ph.D., C.Chem., C.Sci., FRSC, FRACI, FIFST, FIMMM, FRSH, FCMI, FEI, FMIC, FPRIM, FPRIS, FMOSTA

President & CEO:

Dato' Marcus K.F. Kam B.E. (Hons.), M.Sc., C.Chem., FRACI, MRSC, MBA, AMIChemE.

Executive Director:

Datin P.K. Wong Dip. NIOA, FRSH, FCMI, FEI

CERTIFICATE OF ANALYSIS

Company : M/s. Excelsia Technologies Sdn. Bhd.
Unit 103, 1st Floor, Lift No. 2, Block C,
Damansara Intan, No. 1, Jalan SS20/27,
47400 Petaling Jaya, Selangor Darul Ehsan.

Lab No : PJ-D/WE/1834/18

Page : 1 of 1

Sample Description : One (1) sample of Solution
Sample Marking : Ultra Mist Solution 250mL
Date Sample Received : 18th October 2018
Date Analyzed : 18th October 2018 – 29th October 2018
Date Reported : 29th October 2018

BACTERIOLOGICAL ANALYSIS :

Parameters	Results
<i>Legionella pneumophila</i>	
Total <i>Legionella</i> Count, organism/ml	No Growth (<10)
<i>Legionella pneumophila</i> serogroup 1 Count, organism/ml	No Growth (<10)
<i>Legionella pneumophila</i> serogroup 2-14 Count, organism/ml	No Growth (<10)
<i>Legionella</i> spp (unidentified) Count, organism/ml	No Growth (<10)

Test Method : AS/NZS 3896:2008

REMARK :

Based on the above laboratory findings, *Legionella pneumophila* was not detected in the sample received.


Sam Loo Y. M.
B.Sc., AMIC
QA Manager

Sampling is not under scope of accreditation.

THE ABOVE ANALYSIS IS BASED SOLELY ON THE SAMPLES SUBMITTED BY THE CUSTOMER

The Department of Standards Malaysia (DSM) is one of the Signatories to the APLAC Mutual Recognition Arrangement (APLAC MRA) for the mutual recognition of test reports.

- This report must not be used for advertising purposes.
- The certificate shall not be reproduced except in full without the written approval of the laboratory.

JOHOR BAHRU BRANCH

Wisma Kam, 52, Jalan Dedap 4,
Taman Johor Jaya, 81100 Johor Bahru,
Johor Darul Takzim, Malaysia.
Tel: 07-3543526 (4 Lines)
Fax: 07-3543527

PENANG BRANCH

298-1-2-3, Jalan Datuk Ismail Hashim,
11900 Sungai Ara, Penang, Malaysia.
Tel: 04-6465277,
04-6467912
Fax: 04-6466260

KUCHING BRANCH

Lot 8805-8806, 3rd Floor, Pending Court,
Jalan Kwong Lee Bank,
93450 Kuching, Sarawak, East Malaysia.
Tel: 082-343841
Fax: 082-343840

SINGAPORE BRANCH

520, Balestier Road # 06-01,
Leong On Building,
Singapore 329853.
Tel: (65) 62536122
Fax: (65) 62504837

THAILAND BRANCH

282 Raintree Office Garden, B3 Building, 3rd Floor,
Soi Soonvijai 4, Rama IX Road, Bangkok 10310 Thailand.
Tel: (662) 719-6488-92
Fax (662) 719-6483